

# Council Carpark Lighting B160.08



## DESIGN STATEMENT

Park lighting is used to illuminate Council-owned carpark. The LED light provides improved energy efficiency.

Higher lighting level for dedicated disabled parking maybe provided if applicable.

## APPLICABLE LOCATION

Council carpark.

## COUNCIL STANDARD DRAWING

N/A

## CROSS REFERENCE DOCUMENT

- AS 1158.6 Lighting for Roads and Public Spaces (Part 6: Luminaires), category P4.

## STANDARD SPECIFICATION

**Luminaire:** RFL530-SE (LED) from WE-EF. 'Classic Silver' 2-pack paint finish.

**Light distribution:** Lenses for light distribution will need to be specified for each project.

**Colour temperatures:** Colour temperatures of 4000K will need to be specified for each project. 3000K may also be used when specifically requested.

**Pole:** Galvanised finish or unless specified, 'Classic Silver' 2-pack paint finish.

**Height:** Minimum luminaire mounting height should be 6 metres.

## SUPPLIER

WE-EF [www.we-ef.com.au](http://www.we-ef.com.au) or similar.

Distributor: Buckford Illumination [www.buckford.com.au](http://www.buckford.com.au) or similar.

## MAINTENANCE

Lighting within Council carpark is metered lighting, maintained by Council Sustainable Transport.

## GENERAL NOTES

- Refer to manufacturer's installation manual



---

# B160.08 Council Carpark Lighting

---

